

MIRTEC's Electrotechnical Products Testing Laboratories**A' Industrial Area, P.O. Box 13, GR-385 00 Volos – GREECE****TEL.: +30-210-228.37.57 – FAX: +30-210-577.05.56****e-mail: electrotechnical.labs@mirtec.gr, Website: www.mirtec.gr****CERTIFICATE OF CONFORMITY**

CERTIFICATE NUMBER : MIRTEC-INST-C-396.1-2020
DATE OF ISSUE : 16-3-2020
ISSUED TO : KOUVIDIS, EMM. S.A
TEST ITEM : Rigid Double structured wall pipe with color identity
TYPE/MODEL : GEOSUB OD250 N450 ø 250
MANUFACTURER : KOUVIDIS, EMM. S.A
APPLICABLE DIRECTIVES : LVD 2016/35/EU
APPLICABLE STANDARDS : EN 61386-24:2010 use in conjunction with
EN 61386-1:2008 +A1:2019

STATEMENT:

The tested item successfully passed the compression, impact and degree of protection provided by enclosures (IP68) tests of cl. 10.2, 10.3 and 14.1 respectively, of the previously mentioned standards.

GENERAL REMARKS :

- The test results apply only to the sample for which the test Reports S/N 100396.1 dated February 18, 2020 was issued.
- The tests were performed in accordance with the above mentioned applicable standards from January 1 up to February 18, 2020
- This certificate is applicable until March 15, 2023.

MIRTEC's Electrotechnical
Products Testing Laboratories
K. KARINIOTAKIS
ELECTRICAL ENGINEER MSc, EE
CERTIFICATION MANAGER

Signed:



KONSTANTINOS KARINIOTAKIS
ELECTRICAL ENGINEER MSc,EE
LAB DIRECTOR

Date of issue: March 16, 2020