

**MIRTEC's Electrotechnical Products Testing Laboratories****A' Industrial Area, P.O. Box 13, GR-385 00 Volos – GREECE****TEL.: +30-210-228.37.57 – FAX: +30-210-577.05.56****e-mail: [electrotechnical.labs@mirtec.gr](mailto:electrotechnical.labs@mirtec.gr), Website: [www.mirtec.gr](http://www.mirtec.gr)****CERTIFICATE OF CONFORMITY**

**CERTIFICATE NUMBER** : MIRTEC-INST-C-396.2-2020  
**DATE OF ISSUE** : 16-3-2020  
**ISSUED TO** : KOUVIDIS, EMM. S.A  
**TEST ITEM** : Rigid Double structured wall pipe with color identity  
**TYPE/MODEL** : GEONFLEX OD250 N750 ø 250  
**MANUFACTURER** : KOUVIDIS, EMM. S.A  
**APPLICABLE DIRECTIVES** : LVD 2014/35/EU  
**APPLICABLE STANDARDS** : EN 61386-24:2010 use in conjunction with  
EN 61386-1:2008 +A1:2019

**STATEMENT:**

The tested item successfully passed the compression, impact and degree of protection provided by enclosures (IP68) tests of cl. 10.2, 10.3 and 14.1 respectively, of the previously mentioned standards.

**GENERAL REMARKS :**

- The test results apply only to the sample for which the test Reports S/N 100396.2 dated February 18, 2020 was issued.
- The tests were performed in accordance with the above mentioned applicable standards from January 1 up to February 18, 2020
- This certificate is applicable until March 15, 2023.

MIRTEC's Electrotechnical  
Products Testing Laboratories  
K. KARINIOTAKIS  
ELECTRICAL ENGINEER MSc, EE  
CERTIFICATION MANAGER

Signed: \_\_\_\_\_

Date of issue: March 16, 2020



KONSTANTINOS KARINIOTAKIS  
ELECTRICAL ENGINEER MSc,EE  
LAB DIRECTOR