




ORIGINAL

MIRTEC's Electrotechnical Products Testing Laboratories
A' Industrial Area, P.O. Box 13, GR-385 00 Volos – GREECE

TEL.: +30-210-228.37.57 – FAX: +30-210-577.05.56

e-mail: electrotechnical.labs@mirtec.gr, Website: www.mirtec.gr

CONFIRMATION OF COMPLIANCE

CONFIRMATION NUMBER : MIRTEC-INST-C-566-E-2023
DATE OF ISSUE : February 17, 2023
ISSUED TO : KOUVIDIS, EMM., S.A
TEST ITEM : Conduits buried underground
TYPE/MODEL : a.- GEOSUB OD250 N450
b.- GEOFLEX OD250 N750
MANUFACTURER : 
APPLICABLE DIRECTIVES : LVD 2014/35/EU
APPLICABLE STANDARDS : EN 61386-24:2010 use in conjunction with
EN 61386-1:2008 +A1:2019

STATEMENT : The test items (GEOSUB OD250 N450 \varnothing 250 and GEOFLEX OD250 N750 \varnothing 250) successfully passed the compression, impact and degree of protection provided by enclosures (IP68) tests of cl. 10.2, 10.3 and 14.1 respectively, of the above mentioned standards.

GENERAL REMARKS :

- The test results apply only to the samples for which the test Reports S/N 100566.1 and 100566.2 dated February 17, 2023, were issued.
- The tests were performed in accordance with the above mentioned applicable standards from February 13, 2023 up to February 17, 2023.
- This confirmation is applicable until February 16, 2026.

MIRTEC's Electrotechnical
Products Testing Laboratories
K. KARINIOTAKIS
ELECTRICAL ENGINEER MSc, EE
LAB DIRECTOR

Signed:



KONSTANTINOS KARINIOTAKIS
ELECTRICAL ENGINEER MSc,EE
LAB DIRECTOR

Date of issue: February 17, 2023